



Model ZSFZ4X9 with ANSI Flange
File Number: EX26840

COMPANY

JINAN MEIDE CASTING CO LTD
Meide Science and Technology Park
Pingyin Industrial Park
JINAN, Shandong Sheng 250400 China

MODEL INFO

ZSFZ4X9 with ANSI Flange
Alarm Valve

PRODUCT INFORMATION

Body Type	Nom Pipe Size, NPS	End Configuration	Max Rated Pressure, psig (kPa)	Supply Pressure Type	Alarm Device Type	Alarm Device Model	Retard Chamber Model	Installed Position
Globe	3, 4, 6	Flange	300 (2068)	Variable	Water motor gong	NX010	YSQ	Vertical
Globe	3, 4, 6	Flange	300 (2068)	Variable	Electric pressure switch	UL Listed (VOXZ)	YSQ	Vertical
Globe	3, 4, 6	Flange	300 (2068)	Constant	Water motor gong	NX010	Not Applicable	Vertical
Globe	3, 4, 6	Flange	300 (2068)	Constant	Electric pressure switch	UL Listed (VOXZ)	Not Applicable	Vertical

GENERAL

Installation Limitations

End configurations are intended to be installed on systems not exceeding end configurations' working capabilities.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."