



Model 1G
File Number: EX6464

COMPANY

JINAN MEIDE CASTING CO LTD
Meide Science and Technology Park
Pingyin Industrial Park
JINAN, Shandong Sheng 250400 China

MODEL INFO

1G
Coupling

COUPLINGS, FLANGE ADAPTERS			
Outlet Type	Pipe Type	Size, NPS (unless otherwise indicated)	Rated Pressure, psig (kPa)
Grooved, Rolled	Sch. 10	1-1/4, 1-1/2, 2-1/2	500 (3447)
Grooved, Rolled	Sch. 10	2, 3, 4, 5, 6	500 (3447)
Grooved, Rolled	Sch. 10	8	500 (3447)
Grooved, Rolled	Sch. 10	10, 12	500 (3447)
Grooved, Rolled	BS 1387 Sch. 10	3 OD, 6-1/2 OD	300 (2068)
Grooved, Rolled	BS 1387 (M)	5-1/2 OD	450 (3102)
Grooved, Cut	Sch. 40	1-1/4, 1-1/2	500 (3447)
Grooved, Cut	Sch. 40	2, 2-1/2, 3, 4, 5, 6	500 (3447)
Grooved, Cut	Sch. 40	8	500 (3447)
Grooved, Cut	Sch. 40	10, 12	500 (3447)
Grooved, Rolled	Sch. 10	14, 16, 18, 20, 24	300 (2068)
Grooved, Cut	Sch. 40	14, 16, 18, 20, 24	300 (2068)
Grooved, Cut	BS 1387 Sch. 40	3 OD, 6-1/2 OD	300 (2068)
Grooved, Cut	BS 1387 (H)	5-1/2 OD	450 (3102)

COUPLINGS, FLANGE ADAPTERS

Outlet Type	Pipe Type	Size, NPS (unless otherwise indicated)	Rated Pressure, psig (kPa)
Grooved, Cut	ISO 4200 (3.2 mm wall thickness)	33.7 mm	500 (3447)
Grooved, Cut	ISO 4200 (4.0 mm wall thickness)	108.0 mm	500 (3447)
Grooved, Cut	ISO 4200 (4.0 mm wall thickness)	159.0 mm	300 (2068)
Grooved, Cut	ISO 4200 (5.4 mm wall thickness)	133.0 mm	300 (2068)
Grooved, Cut	JIS G3454 Sch. 20	267.4 mm, 318.5 mm	225 (1551)
Grooved, Cut	ISO 4200 (6.3 mm wall thickness)	355.6 mm, 406.4 mm	175 (1206)

NOTES

Notes

Suitable for use in dry pipe systems for temperatures to 40 F

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."