FM Approvals
Member of the FM Global Group

Pipes/Fittings/Couplings | Aboveground Pipe and Fittings | Steel Pipe, Schedule 40

Schedule 40 b,c,d

Details

Category	Steel Pipe, Schedule 40
Class of Work	1630 - Steel Pipe Spklr Sys Serv
Approval Standard	FM 1630 - Steel Pipe for Automatic Fire Sprinkler Systems
Certification Type	FM Approved
Nominal Pipe Size, mm(in.)	1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8
Rated Working Pressure, psi	300
Rated Working Pressure, kPa	2070
Listing Country	Oman
Footnote Reference	b -FM Approved for use with FM Approved pipe fittings when threaded.
	c -FM Approved for use in welded systems when supplied with standard bevel on both ends.
	d -When hot dip galvanized by factory, the sprinkler pipe if FM Approved for dry pipe systems.

Company

Al Jazeera Steel Products Co SOAG
P.O. Box 40 , Postal Code 327,
Sohar Industrial Estate, Sohar,
Sultanate of Oman
Oman
http://jazeerasteel.com