FM Approvals
Member of the FM Global Group

Sprinklers | Non-Storage Sprinklers | Non-Storage Sprinklers

TY3111

Details

Category	Non-Storage Sprinklers
Class of Work	2016 - AS, Control Mode, Upright
Approval Standard	FM 2000 - Automatic Sprinklers for Fire Protection
Certification Type	FM Approved
K (metric)	80
Coverage Type	Standard
Sprinkler Category	Non Storage
Use with Vacuum System	No
Grooved Connection	No
K	5.6
Type	Upright
Response	SR - Standard Response
Element	Fusible
NPT (in.)	1/2
Finish	Lead, Wax
Temp. Rating (°F)	165, 212
Temp. Rating (°C)	74, 100
Listing Country	United States of America

Company

Tyco Fire Products LP
1467 Elmwood Ave, Cranston ,
Rhode Island 02910
United States of America
http://tyco-fire.com


FM Approvals
Member of the FM Global Group