FM Approvals
Member of the FM Global Group

Sprinklers | Non-Storage Sprinklers | Non-Storage Sprinklers

TY3311

Details

Category	Non-Storage Sprinklers
Class of Work	2012 - AS, Control Mode, Sidewall
Approval Standard	FM 2000 - Automatic Sprinklers for Fire Protection
Certification Type	FM Approved
K	5.6
K (metric)	80
Coverage Type	Standard
Type	Horizontal Sidewall
Response	SR - Standard Response
Element	Fusible
Finish	Brass, Chrome
Temp. Rating (°F)	165, 212, 280
Temp. Rating (°C)	74, 100, 138
Sprinkler Category	Non Storage
Use with Vacuum System	No
Grooved Connection	No
NPT (in.)	1/2
Listing Country	United States of America

Company

Tyco Fire Products LP
1467 Elmwood Ave, Cranston ,
Rhode Island 02910
United States of America
http://tyco-fire.com


FM Approvals
Member of the FM Global Group