FM Approvals
Member of the FM Global Group

Sprinklers | Non-Storage Sprinklers | Non-Storage Sprinklers

TY4151

Details

Category	Non-Storage Sprinklers
Class of Work	2001 - AS, Ctrl Mode (nom K=8.0)
Approval Standard	FM 2000 - Automatic Sprinklers for Fire Protection
Certification Type	FM Approved
K	8.0
K (metric)	115
Coverage Type	Standard
Type	Upright
Response	SR - Standard Response
Element	5 mm
Finish	Wax
Temp. Rating (°C)	57, 68, 93, 141
Sprinkler Category	Non Storage
Use with Vacuum System	No
Grooved Connection	No
NPT (in.)	3/4
Temp. Rating (°F)	135, 155, 200, 286
Listing Country	United States of America

Company

Tyco Fire Products LP
1467 Elmwood Ave, Cranston ,
Rhode Island 02910
United States of America
http://tyco-fire.com


FM Approvals
Member of the FM Global Group