FM Approvals

Valves | Indicating Valves (Butterfly or Valve Type) | **Indicating Valves, Butterfly or Ball Type**

Models BFV-300, BFV-300C, BFV-250

Product Description

Model No	Description	Valve Size		Rated Working Pressure		Remarks
		in	(mm)	psi	(kPa)	
BFV-300 Grooved	Butterfly Valve, Grooved Ends	2 1/2, 3, 4, 5, 6	(65, 80, 100, 125, 150)	300	(2065)	a, b, c
BFV-300C Grooved	Butterfly Valve, Grooved Ends	2 1/2, 3, 4, 5, 6	(65, 80, 100, 125, 150)	300	(2065)	a, b, c, e
BFV-300 Grooved	Butterfly Valve, Grooved Ends	8	(200)	300	(2065)	a, b, c
BFV-300C Grooved	Butterfly Valve, Grooved Ends	8	(200)	300	(2065)	a, b, c, e
BFV-300 Wafer	Butterfly Valve, Wafer Body	2 1/2, 3, 4, 5, 6, 8	(65, 80, 100, 125, 150, 200)	300	(2065)	a, b, c
BFV-250 Wafer	Butterfly Valve, Wafer Body	2 1/2, 3, 4, 5, 6, 8	(65, 80, 100, 125, 150, 200)	250	(1720)	a, b, c
BFV-250 Wafer	Butterfly Valve, Wafer Body	10	(250)	175	(1205)	a, b, c
BFV-300 Grooved	Butterfly Valve, Grooved Ends	10	(250)	175	(1205)	a, b, c
BFV-300C Grooved	Butterfly Valve, Grooved Ends	10	(250)	175	(1205)	a, b, c, e
BFV-300 Wafer	Butterfly Valve, Wafer Body	10	(250)	175	(1205)	a, b, c

Remarks:

a. Available with dual supervisory switches.

b. FM Approved for indoor and outdoor use.

c. FM Approved for aboveground installations only.

d. FM Approved indoor service only.

e. These valves cannot be installed between the fire protection system water source and sprinkler heads. Intended for use in fire pump test bypass lines only..

FM Approvals

Details

Category	Indicating Valves, Butterfly or Ball Type
Class of Work	1112 - Indicating Valves
Approval Standard	FM 1112 - Indicating Valves (Butterfly or Ball Type)
Certification Type	FM Approved
Listing Country	United States of America

Company

Tyco Fire & Building Products
1467 Elmwood Ave, Cranston ,
Rhode Island 02910
United States of America
http://tyco-fire.com