UL Product iQ®

Model CV-1F

File Number: EX6218

COMPANY

TYCO FIRE & BUILDING PRODUCTS
1467 ELMWOOD AVE
CRANSTON, RI 02910-3849 United States

MODEL INFO

CV-1F
Swing

ATTRIBUTES AND RATINGS

Valve Seat Facing	Nom Pipe Size, NPS	End Configuration	Rated Pressure, psig (kPa)	Installation Position
Elastomeric	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12, 50.8 mm, 76.1 mm, 139.7 mm, 165.1 mm, 267.4 mm	Groove	300 (2068)	Horizontal, Vertical

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."