UL Product iQ™

# HMER.EX6218 - Check Valves

## Check Valves

See General Information for Check Valves

**TYCO FIRE & BUILDING PRODUCTS** EX6218
1400 PENNBROOK PKWY
LANSDALE, PA 19446-3840 USA

| Model | Type | Valve Seat Facing | Nom Pipe Size, NPS | End Config | Rated Pressure, psig | Installation Position |
|---|---|---|---|---|---|---|
| CV-1 | Swing | Elastomeric | 2, 2-1/2, 3, 4, 5, 6, 8, 10, 12, (50.8, 76.1, 139.7, 165.1, 273 mm) | G | 300 | H, V |
| CV-1F | Swing | Elastomeric | 2, 2-1/2, 3, 4, 5, 6, 8, 10, 12, (50.8, 76.1, 139.7, 165.1, 273 mm) | G | 300 | H, V |
| CV-1FR | Swing | Elastomeric | 2, 2-1/2, 3, 4, 5, 6, 8, 10, 12, (50.8, 76.1, 139.7, 165.1, 273 mm) | G | 300 | H, V |
| TJCV | Swing | Elastomeric | 2, 2-1/2, 3, 4, 5, 6, 8, 10, 12 | F by F | 300 | H, V |

End Configuration:

G - Grooved

Installation Position:

H - Horizontal installation

V - Vertical installation

Trademark and/or Tradename: "CSC"

Last Updated on 2020-10-27

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2021 UL LLC"