FM Approvals
Member of the FM Global Group

Sprinklers | Non-Storage Sprinklers | Non-Storage Sprinklers

TY323

Details

Category	Non-Storage Sprinklers
Class of Work	2017 - AS, Control Mode, Pendent
Approval Standard	FM 2000 - Automatic Sprinklers for Fire Protection
Certification Type	FM Approved
K (metric)	80
Coverage Type	Standard
Sprinkler Category	Non Storage
Use with Vacuum System	No
Grooved Connection	No
K	5.6
Type	Pendent
Response	QR - Quick Response
Element	3 mm
NPT (in.)	1/2
Finish	Brass, Chrome, Polyester
Temp. Rating (°F)	135, 155, 175, 200, 286
Temp. Rating (°C)	57, 68, 79, 93, 141

Company

Tyco Fire Products LP
1467 Elmwood Ave, Cranston ,
Rhode Island 02910
United States of America
http://tyco-fire.com

FM Approvals®

Member of the FM Global Group

Listing Country	United States of America