UL Product iQ®

SIN TY323

File Number: EX5985

COMPANY

TYCO FIRE & BUILDING PRODUCTS
1467 ELMWOOD AVE
CRANSTON, RI 02910-3849 United States

SIN INFO

TY323
Glass Bulb Type

ATTRIBUTES

Response Type	Sprinkler Type	Nom K-Factor, gpm/vpsi (L/min/vbar)	System Working Pressure	Corrosion Resistant
QR	Standard-Spray Sprinklers, Upright And Pendent, Intermediate Level Sprinklers	5.6 (80)	250 psig (1.7 Mpa)	Non-Wax Coatings - See installation instructions

GENERAL

Inlet Connection
1/2 in. NPT

STANDARD-SPRAY SPRINKLERS, UPRIGHT AND PENDENT

Type	Sprinkler Temp Rating, °F (°C)	Cover Temp Rating, °F (°C)
Pendent	135 (57), 155 (68), 175 (79), 200 (93), 286 (141)	Not Applicable
Rec. Pendent	135 (57), 155 (68), 175 (79), 200 (93)	Not Applicable

INTERMEDIATE LEVEL SPRINKLERS

Type	Sprinkler Temp Rating, °F (°C)
Pendent	135 (57), 155 (68), 175 (79), 200 (93), 286 (141)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."