FM Approvals
Member of the FM Global Group

Sprinklers | Non-Storage Sprinklers | Recessed, Flush, and Concealed Sprinklers

TY3521

Details

Category	Recessed, Flush, and Concealed Sprinklers
Class of Work	2015 - AS, Ctrl Md, Rec Fl & Concld
Approval Standard	FM 2000 - Automatic Sprinklers for Fire Protection
Certification Type	FM Approved
K (metric)	80
Coverage Type	Standard
Sprinkler Category	Non Storage
Use with Vacuum System	No
Grooved Connection	No
K	5.6
Type	Concealed Horizontal Sidewall
Response	SR - Standard Response
Element	Fusible
NPT (in.)	1/2
Finish	Brass
Temp. Rating (°F)	165, 212
Temp. Rating (°C)	74, 100

Company

Tyco Fire Products LP
1467 Elmwood Ave, Cranston ,
Rhode Island 02910
United States of America
http://tyco-fire.com

FM Approvals®

Member of the FM Global Group

Listing Country	United States of America