FM Approvals

Other Fire Protection Products | Waterflow Alarm Indicators (Vane Type) | Waterflow Detectors, Vane Type

Model TF020, 25, 30, 40, 50, 60, 80

Product Description

Rated working pressure of 450 psi (3105 kPa). Two snap switches and pneumatic retard.

All sizes rated for Schedule 10 and 40 pipe.

Product Specification

Model No	Valve Size	
	in	(mm)
TF020	2	(50)
TF025	2 1/2	(65)
TF030	3	(80)
TF040	4	(100)
TF050	5	(125)
TF060	6	(150)
TF080	8	(200)

Details

Category	Waterflow Detectors, Vane Type
Class of Work	1043 - Waterflow Tester (vane type)
Approval Standard	FM 1043 - Water Flow Detector Testers 1 in. Through 8 in. Nominal Size
Certification Type	FM Approved

Company

Tyco Fire & Building Products
1467 Elmwood Ave, Cranston ,
Rhode Island 02910
United States of America
http://tyco-fire.com

FM Approvals

Listing Country	United States of America