UL Product iQ®

Extinguishing System Attachments

COMPANY

TYCO FIRE & BUILDING PRODUCTS
1467 ELMWOOD AVE
CRANSTON, RI 02910-3849 United States

S36578

SPRINKLER SYSTEM ALARM INITIATING DEVICES

Wet pipe, paddle type

Model	Size In.	Pipe Schedule	Max System Pressure psig
TF010	1.00	10 thru 40	450
TF012	1.25	10 thru 40	450
TF015	1.50	10 thru 40	450
TF021	2.00	10 thru 40	450
TF020	2	10 thru 40	450
TF025	2.5	10 thru 40	450
TF030	3	10 thru 40	450
TF040	4	10 thru 40	450
TF050	5	10 thru 40	450
TF060	6	10 thru 40	450
TF080	8	10 thru 40	450
TF100	10	10 thru 40	300
TF020-EX	2	10 thru 40	300
TF025-EX	2.5	10 thru 40	300
TF030-EX	3	10 thru 40	300
TF040-EX	4	10 thru 40	300
TF050-EX	5	10 thru 40	300
TF060-EX	6	10 thru 40	300

TF080-EX	8	10 thru 40	300
TF010-T	1.0	10 thru 40	300
TF012-T	1.25	10 thru 40	300
TF015-T	1.5	10 thru 40	300
TF020-T	2.0	10 thru 40	300

SUPERVISORY SIGNAL INITIATING DEVICES

Supervisory switches

Model	**Oper Pressure psig**	**Max System Pressure psig**
TOSY-1	N/A	N/A
TOSY-2	N/A	N/A
TIP-1	N/A	N/A
TIP-2	N/A	N/A
TSS	N/A	N/A

Last Updated on 2022-05-02

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."