FM Approvals

Sprinkler Supervisory Switch

Certificate Number: FM24US0177

Company

TMPMAX Canada Inc.
3551 St. Charles Blvd., Suite 624, Kirkland , Quebec H9H3C4
Canada
http://tmpmax.com

Detection, Fire Alarm and Signaling Equipment | Sprinkler Valve Position Devices | Sprinkler System Supervision, Standard Security

TOSY Sprinkler Supervisory Switch

Description of Equipment:

TOSY Sprinkler Supervisory Switch

Operating Specifications	**TOSY**
Switch Contact Ratings	10.1A@125/250VAC 2.A@24VDC
Connection	Bolt on
Operating Temperature Range	0℃ to 60℃
Suitable location of operation	Indoor use only

Details

Category	Sprinkler System Supervision, Standard Security
Class of Work	3135 - Sprinkler Valve Pos Sw
Certification Type	FM Approved
Listing Country	Canada

FM Approvals

Certificate Number	FM24US0177