Approvals

Sprinklers | Storage Sprinklers | Storage Sprinklers

TY5151

Details

Category	Storage Sprinklers
Class of Work	2009 - AS, Ctrl Md (nom K=11.2)
Approval Standard	FM 2000 - Automatic Sprinklers for Fire Protection
Certification Type	FM Approved
K (metric)	160
Coverage Type	Standard
Sprinkler Category	Storage
Use with Vacuum System	No
Grooved Connection	No
K	11.2
Type	Upright
Response	SR - Standard Response
Element	5 mm
NPT (in.)	3/4
Finish	Lead, Chrome, Brass
Temp. Rating (°F)	155, 200, 286
Temp. Rating (°C)	68, 93, 141
Listing Country	United States of America

Company

Tyco Fire Products LP
1467 Elmwood Ave, Cranston ,
Rhode Island 02910
United States of America
http://tyco-fire.com