UL Product iQ®

SIN TY3255

File Number: EX5985

COMPANY

TYCO FIRE & BUILDING PRODUCTS
1467 ELMWOOD AVE
CRANSTON, RI 02910-3849 United States

SIN INFO

TY3255
Glass Bulb Type

ATTRIBUTES

Response Type	Sprinkler Type	Nom K-Factor, gpm/vpsi (L/min/vbar)	System Working Pressure	Corrosion Resistant
SR	Dry-Type Sprinklers, Upright And Pendent	5.6 (80)	175 psig (1.2 Mpa)	Not Available

GENERAL

Inlet Connection
1/2 in. NPT

DRY-TYPE SPRINKLERS, UPRIGHT AND PENDENT

Type	Max Length, in. (m)	Sprinkler Temp Rating, °F (°C)	Cover Temp Rating, °F (°C)
Dry Pendent	48 (1.2)	135 (57), 155 (68), 175 (79), 200 (93), 286 (141), 360 (182)	Not Applicable
Dry Rec. Pendent	48 (1.2)	135 (57), 155 (68), 175 (79), 200 (93), 286 (141)	Not Applicable

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."