UL Product iQ®

Note: In the process of enhancing our systems, we are transitioning data to a new PiQ data view. This data is being verified with the "Historical" view for accuracy. Once the data is confirmed, the "Historical" view will be discontinued. During this transition, you may encounter duplicate entries or missing/outdated data. For queries during this interim period, please visit our Historical View FAQs or contact our Customer Service.

Valves, Alarm

COMPANY

TYCO FIRE & BUILDING PRODUCTS
1467 ELMWOOD AVE
CRANSTON, RI 02910-3849 United States

EX6872

Alarm valves, Model AV-1-175 in the sizes 2-1/2, 4, 6, 8 in. for horizontal or vertical installation with the following end connections: flanged-flanged, flanged-grooved and grooved-grooved and for rated pressures not exceeding 175 psig.

Model AV-1-300 in the sizes 2-1/2, 4, 6, 8 in. for horizontal or vertical installation with the following end connections: flanged-flanged, flanged-grooved and grooved-grooved and for rated pressures not exceeding 300 psig.

Model RC-1 retarding chamber, Model WM-1 "Y" strainer, Model WMA-1, water motor and gong all for rated pressures not exceeding 300 psig.

Models AV-1-175, AV-1-300 valves may be provided with flanged connections drilled per ANSI, AS, ISO, and JIS specifications.

Trademark and/or Tradename: "CSC"

Last Updated on 2023-02-08

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL Solutions' Follow - Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL Solutions' Follow - Up Service. Always look for the Mark on the product.

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2024 UL LLC."